

eco-INSTITUT, Schanzenstr. 6-20, Carlswerk 1.19, D-51063 Köln

Tambour Ltd.
 2 Moshe Borenstein str, Industrial Zone, P.O.B 2238
 IL 2412102 Akko

Dear Dear Sir or Madam,

based on the evaluation of Test report **59094-A001-AgBB-L** dated **05/06/2024**, for the product **Superboard Plasterboard**, commissioned by **Tambour Ltd.**, we confirm compliance with the requirements of:

- VOC product emissions acc. to EN 16516:2020-10 and LCI values from Table 1 of the AgBB Scheme 2021 after 28 days

These criteria meet the requirements for low-emitting **Wall panels** in credit EQc2 of the LEEDv4 Rating System and the LEEDv4.1 Rating System for projects outside the US.

Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:

Loading factor	Individual VOCs of Concern		Formaldehyde		TVOC
	Requirement	Requirement hold	Requirement	Requirement hold	Range
1.0 m ² /m ³ for wall products	< LCI	yes	≤ 10 µg/m ³	yes	≤ 0.5 mg/m ³

Mass per surface area: not applicable

Köln, 06/06/2024



Marc-Anton Dobaj, M.Sc. Crystalline Materials
 (Project management)